



RELIEF VALVE REQUIREMENT WHEN GROUND WATER IS ENCOUNTERED

1. During the steel and bonding inspection, the hydrostatic relief valve assembly shall be inspected by the field inspector.
2. Inspection of the hydrostatic relief valve assembly requires that:
 - a.) Gravel blanket to be placed to all wet areas.
 - b.) Ground water to be pumped below level of valve.
 - c.) Sump body steel to be in place.

